PLAN

ELEVATION

BARRIER END DETAIL

GENERAL NOTES

1. Concrete shall be constructed by Cast-In-Place using fixed forms.
2. Concrete shall be Class A, design strength f'c = 3000 psi.
3. All reinforcing steel shall have 2" minimum clear cover unless otherwise noted.
4. All bend dimensions for reinforcing steel shall be out-to-out of bars.
5. See Plans for approach slab details

MARICOPA COUNTY DEPARTMENT OF TRANSPORTATION	BRIDGE BARRIER TRANSITION	DATE:	DETAIL NO.
STANDARD DETAIL		12/15/2015	2812-2