ITEM	QTY.	DESCRIPTION
1	1	METER (SUPPLIED BY UTILITY COMPANY)
2	1	SERVICE PEDESTAL
3	-	2" PVC CONDUIT RUN
4	1	PVC CONDUIT SERVICE RUN (SIZE AS REQ.BY POWER CO)
5	1	NO. 5 PULL BOX (IF REQUIRED BY POWER COMPANY)
6	1	POWER COMPANY POLE

NOTES:

1. SEE PLANS FOR DIRECTION OF PVC CONDUIT RUNS
2. POWER SOURCE MAY COME FROM PAD MOUNTED TYPE TRANSFORMER.
3. METER FACES TOWARD ROADWAY.

TYPE 5 (SERVICE)

MARICOPA COUNTY DEPARTMENT OF TRANSPORTATION	UNDERGROUND POWER SERVICE TO SERVICE PEDESTAL	DATE:	DETAIL NO.
STANDARD DETAIL		01/01/2011	4798